

UNION TERRITORY F JAMMU AND KASHMIR
OFFICE OF THE BLOCK MEDICAL OFFICER MANJAKOTE

E-mail:- bmomanjakote@gmail.com

HEALTH AND SANITATION CERTIFICATE

It is to certify that undersign visited to CHRIST SCHOOL RAJOURI at Village Muradpur P.O Bathuni District & Tehsil Rajouri and found that said school is having M.I Room with first aid facilities, Emergency medicine with having two beds and have transferal facility in case of referral. Sanitation cleanliness is well maintain in this school

No:- BMO/MKT/ 455
DATED:- 25-08-2021


Block Medical Officer
Manjakote

Copy to the:-

01. Principal Christ School Rajouri for information in reference to his application Dated 25/08/2021
02. Office copy.

WATER TESTING LABORATORY PHE KOTRANKA (SUB DIVISION)

Test-Report

No.PHER/WQC/TR/_____

Dated:- 27-7-2021

S.No	Detail	
1.	Location & Address of the Sampling Point	Bore well/Christ school
2.	Name of the Village / Habitation	Christ school
3	Name of District	Rajouri
4.	Type of Source	Bore well
5	Date of Testing	27-7-2021
6.	Collected by	

Water Quality Result

S.No	Water Quality Parameters	BIS Guide lines allowable limits	Value (mg/lit)
1	Appearance	Color less	None
2	Odor	None	None
3.	Turbidity	< 10 N.T.U>	0.60 N.T.U
4.	pH	6.5-8.5	6.52
5	TDS	2000 mg/lit	173 mg/lit
6	Alkalinity	600 mg/lit	183 mg/lit
7	Hardness	600 mg/lit	50 mg/lit
8.	Calcium	<200 mg/lit	20 mg/lit
9	Chloride	1000 mg/lit	20 mg/lit
10.	Fluoride	1.5 mg/lit	0.0 mg/lit
11.	Iron	1.0 mg/lit	Nil mg/lit
12.	Ammonia	1.0 mg/lit	— mg/lit
13.	Aluminium	0.2 mg/lit	— mg/lit
14.	Nitrate	45 mg/lit	10 mg/lit
15.	Phosphate	1.0 mg/lit	Nil mg/lit
16.	Residual Chlorine	0.2 mg/lit	— mg/lit
17.	Coliform count per 100 ml of water	0-3 c.f.u	—

Report:- Water is Fit / Un Fit for drinking purposes.

Checked By:-

Technical Officer
PHE Sub Div HO

Chemist

Lab. Assistant